

# Annexure C

Appendix-XIII

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 458

Dated: 08/08/2026

It is certified that an inspection team headed by Pravin Kumar Singh  
(Name of Officers with designation) from Junior Engineer (PHED Siwan)  
(Name of Department/ Office) inspected the PHED Siwan  
(Name & Address of the school) on 03/08/26 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 1 year

Signature with Seal: Harsh Pratap  
02/08/26

Name : HARSH PRATAP

Designation : ASSISTANT Engineer

Assistant Engineer for  
the Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name & Address of the Office / Department : .....

To

IQRA PUBLIC SCHOOL

Haque Nagar, Syadpur, Siwan

Pin- 841226

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

Government of Bihar

Public Health Engineering Department

District Level Water Testing Laboratory:- Siwan

Sample Collected by- IQRA PUBLIC SCHOOL, SURAPUR

Sample Receiving date:-07.08.2026

| 1                             | Date Of Testing | Block | Panchyat | Name of School             | Parameters         |       |    |     |      |       |     |       |       |      |                 |                 |      |            |    |     |     |
|-------------------------------|-----------------|-------|----------|----------------------------|--------------------|-------|----|-----|------|-------|-----|-------|-------|------|-----------------|-----------------|------|------------|----|-----|-----|
|                               |                 |       |          |                            | pH                 | Turb. | EC | TDS | TH   | Ca    | Mg  | Cl    | Alka. | Fe   | NO <sub>3</sub> | SO <sub>4</sub> | F    | Total Coli |    |     |     |
| 1                             | 08.08.2026      | Siwan | Nagar    | IQRA Public School,Surapur | 7.13               | 0.9   | -  | 189 | 78.9 | 20.30 | 7.3 | 15.60 | 32.60 | 0.21 | BDL             | 10              | 0.21 | <1.1       |    |     |     |
|                               |                 |       |          |                            | Acetabable Limit   |       |    |     | 6.5  | 1.0   | -   | 500   | 200   | 75   | 30              | 250             | 200  | 1.0        | 45 | 200 | 1.0 |
| IS: 10500:2012 (2nd Revision) |                 |       |          |                            | Permissible Limits |       |    |     | 8.5  | 5.0   | -   | 200   | 600   | 200  | 100             | 1000            | 600  | NR         | NR | 400 | 1.5 |

*08/08/26*

Chemist

P.H. Division, Siwan